

**AMENDED CERTIFICATE OF APPROVAL
NON-MUNICIPAL DRINKING WATER SYSTEMS**
NUMBER 5540-94DKYC
Issue Date: February 4, 2013

Township of Osgoode Care Centre
7650 Snake Island Rd
Metcalf, Ontario
K0A 2P0

Site Location: 7650 Snake Island Rd, Metcalf
Ottawa City
K0A 2P0

Pursuant to the Safe Drinking Water Act, 2002, S.O. 2002, c. 32, and the regulations made thereunder and subject to the limitations thereof, this approval is issued under Part VI of the Safe Drinking Water Act, 2002, S.O. 2002, c. 32 to:

PART 1 - DRINKING-WATER SYSTEM DESCRIPTION

- 1.1 With respect to Relief from Regulatory Requirements for the drinking water system serving Township of Osgoode Care Centre in Ottawa City.

PART 2 - DEFINITIONS AND INFORMATION

- 2.1 Words and phrases not defined in this approval shall be given the same meaning as those set out in the *Safe Drinking Water Act, 2002*, S.O. 2002, c. 32 and any regulations made in accordance with that act, unless the context requires otherwise.

- 2.2 In this approval

"approval" means this entire approval document, issued in accordance with section 36 of the *SDWA*, and includes any schedules to it;

Director means a Director appointed pursuant to s. 6 of the *SDWA* for the purposes of Part VI of the *SDWA* ;

"drinking-water system" includes the works set out in Part 1;

"Owner" means Township of Osgoode Care Centre, and includes its successors and assignees;
and

"SDWA" means the *Safe Drinking Water Act, 2002, S.O. 2002, c. 32*, as amended.

PART 3 - RELIEF FROM REGULATORY REQUIREMENTS

Relief from regulatory requirements

- 3.1 Notwithstanding the provisions of O. Reg 170/03, the Owner is not required to comply with its following requirements:
- (a) Section 12-3(1) and (3) of Schedule 12; and
 - (b) Section 8-4(1) of Schedule 8.

Conditions in exchange for relief from regulatory requirements

- 3.2 The Owner shall ensure that at least one distribution sample is taken every month and is tested for the following:
- (a) *Escherichia coli* ;
 - (b) Total coliforms;
 - (c) Free chlorine residual; and
 - (d) Turbidity.
- 3.3 The Owner shall ensure that the sample taken per 3.2 above is in addition to any other sampling required per O. Reg. 170/03.
- 3.4 The Owner shall ensure that the sample taken per 3.2 above is taken at a location and day different from the distribution samples required by Section 12-2 of Schedule 12 of O. Reg. 170/03.

SCHEDULE - A

The following supporting documents form part of this approval:

1. Application dated October 10, 2012 along with all supporting documentation including electronic mail and fax correspondence between the Ministry of the Environment and the Township of Osgoode Care Centre.

This Certificate of Approval revokes and replaces Certificate(s) of Approval No. 9371-7TTHH6 issued on July 23, 2009.

All or part of this decision may be reviewable in accordance with the provisions of Part X of the SDWA. In accordance with Section 129(1) of the Safe Drinking Water Act, Chapter 32 Statutes of Ontario, 2002, as

amended, you may by written notice served upon me and the Environmental Review Tribunal within 15 days after receipt of this notice, require a hearing by the Tribunal. Section 129(2) sets out a procedure upon which the 15 days may be extended by the Tribunal. Section 129(3) of the Safe Drinking Water Act, Chapter 32 Statutes of Ontario, 2002, provides that the Notice requiring the hearing shall state:

1. The aspect of the decision, including the portion of the permit, licence, approval, order or notice of administrative penalty in respect of which the hearing is required; and
2. The grounds for review to be relied on by the person at the hearing.

Except with leave of the Tribunal, a person requiring a hearing in relation to a reviewable decision is not entitled to,
(a) a review of an aspect of the decision other than that stated in the notice requiring the hearing; or
(b) a review of the decision other than on the grounds stated in the notice

The Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Certificate of Approval number;
6. The date of the Certificate of Approval;
7. The name of the Director;
8. The municipality within which the works are located;

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, 15th Floor
Toronto, Ontario
M5G 1E5

AND

The Director
Part VI, *Safe Drinking Water Act, 2002*
Ministry of the Environment
2 St. Clair Avenue West, Floor 12A
Toronto, Ontario
M4V 1L5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the**

Tribunal at: Tel: (416) 314-4600, Fax: (416) 314-4506 or www.ert.gov.on.ca

The above noted water works are approved under Part VI of the Safe Drinking Water Act.

DATED AT TORONTO this 4th day of February, 2013



Aziz Ahmed, P.Eng.
Director

ZB/

c: District Manager, MOE Ottawa
Cindy Robinson-Schoenfeld, Township of Osgoode Care Centre